

Combine Trading Enterprise Pte Ltd

Blk 9012 Tampines Industrial Park A #01-181/183

Singapore 528845

Preventive Maintenance Checklist (COOLING TOWER)

Job at : _____

Type of Service : Routine Servicing of Air-Conds.

Location/Building : _____

Date of Maintenance : _____

Technician Incharge : _____

Remarks : _____

Servicing Location					
Type					
Brand					
Model					
Wash infills by using high pressure jet when necessary					
Clean and wash drip pan and change new water					
Clean sprinkle head and arms					
Visually check valves, bypass valve and float valve. Adjust when necessary					
Check water level					
Lubricate motor bearings					
Check V-belts adjust when necessary					
Inspect on corroded brackets, mountings and pipes					

*Place a tick or record the readings in the space for items done
Indicate with N.A for items not applicable*